

## Update for July / 23

### Landfill

- no issues,Site mowed and loose garbage picked
- bins changed as required

### Water plant & Distribution system

- New uf cleaning chemical returned the filters to like new condition from when they where installed, testing maintenance wash dosages
- Pilot will start in Sept for raw water
- Procedure needs to be established on priority of distributed water, who will be curtailed in case of low levels, what is a low level?
- We will be trying different doses of alum as a coagulant, old alum will be disposed of and hopefully we get good results
  
- Still need ideas to unload the constant demand on plant, screen shots show run hours and peak usage rates, its not sustainable.
- tank mods completed ,nothing is bypassing contact tank
- blend is now 1.9 lts per second

### Equipment and Tools -routine equipment maintenance and repairs on going

- Truck blade need some parts,still sourcing

### Town buildings- Checking and repairing as required , hvac inspection completed

- Overhead door in the shop had a spring fail, repaired now

### Education-

### Lagoon/sewer- Concrete at lagoon for erosion control

- All manhole bottoms are now repaired
- Lagoon manholes where inspected, will be jetted at a later date along with wetland valve assembly

### Grass / Trees – mowing continuing , tree trimming has begun on boulevard trees,spraying as well

- Tree medics scheduled for tree work this fall

### Streets – AWS completed pavement patches