

Update for AUGUST/ 22

Landfill

- landfill mowed and trees piled
- 6 rat bait stations around site, feeding slowing
- bins changed as required

Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

- New membranes on site, awaiting cleaning chemicals to practice on uf
- Cleaned both uf and ro with new chemicals, worked well on organics
- Blend is now 1.0 LT/S-Issues with turbidity and chlorine
- cleaning approximately once per week, new chemicals working awesome
- Checking on internet security/water plant dial in program-Delco
- Need clarification on uf integrity testing, daily or on runtime
- Lake pump pulled –cleaned intake screen, good flow now
- hydrant inspection completed , had to rebuild #1 hydrant seat assembly, #18 hydrant, seat issues, scheduled for repair sept.
- 3” LAKE Line ruptured Repaired sept 8/land reclamation is required

Equipment and Tools -routine equipment maintenance and repairs on going

- Service equipment as required
- Serviced mini mag hall floor cleaner, needs lots of parts ,ordered

Town buildings-no issues –monitoring as required

- Changed 6 lights in gym
- Hvac inspections completed, changed all filters ,belts okay
- Canteen water issues with hose failure , cleaned up and will repair hose etc

Education

- Book Perry for class #1 ?

Lagoon/sewer-,actizyme being added, logging and testing on going

- inspected all manholes, 13 where cleaned and 4 bottoms need repair, Quote recieved

Grass / Trees- - Mowing as required ,Tree medic contacted and will schedule

- removed and cleaned up trees from various storms, trimming boulevard trees

Streets – Ongoing maintenance ,Streets swept, weed spraying ongoing

Safety - oh&s on site, not many issues ,Jamie has report