

Update for MAY / 23

Landfill

- no issues
- bins changed as required, steel bin on site , have to do a bit of site cleanup , paying to dump metal?

Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

- Report for filter autopsy and cleaning study received and reviewed
- Pilot will start in June for raw water
- Lake has turned and noticing changes in uf operation now
- doing a uf clean in place every three to four days to maintain flow, 5-hour process
- Chemicals ordered for uf cleaning, hopefully we get good results
- Cistern water piped into uf tanks for new cleaning procedures
- Procedure needs to be established on priority of distributed water, who will be curtailed in case of low levels, what is a low level?
- Avonlea east pipeline now has a curb stop to isolate them in case of issues
- KGS -Ashref Darbi on site April 12th , discussed issues with the plant, lake line , uf fouling issues , ro fouling and performance
- WSA, don turner , rod on site for a request to modify operating procedure on uf ,as well as lagoon inspection
- Dillion and Baback here with drop water, calibrations , plant walk through,marlynn and Raymond met and discussed path forward. We will add a coagulant up front and proceed with pilot study on raw water.
- Usage still going up as park gears up and gardens blooming, redthorpe line usage is increasing
- Still need ideas to unload the constant demand on plant , screen shots show run hours and peak usage rates, its not sustainable.

Equipment and Tools -routine equipment maintenance and repairs on going

- F-915- gearbox failed on mower ,part is obsolete, found one at long creek vintage mower parts storage
- Truck blade need some parts, sourcing as required
- Skid steer repaired- cylinder piston issues

Town buildings- Checking and repairing as required , hvac inspection scheduled for next week

Education-

Lagoon/sewer- Top shot was on site and quote given, scheduled for this month possibly. Manhole data base is now built, manholes will be numbered along with a picture to compare previous year to and log work already completed or scheduled .Lagoon Inspected by WSA ,few things to complete ,report to follow

- Lagoon manholes where inspected , will be jetted at a later date along with wetland valve assembly

Grass / Trees -Mowing has begun , not many issues, weather mainly

Streets – Ongoing maintenance , Scott for APS on site for quote this week