

Update for SEPT/ 22

Landfill

- landfill mowed and trees Piled as required
- bins changed as required

Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

- New membranes on site, awaiting cleaning chemicals to practice on uf
- Cleaned both uf and ro with new chemicals, worked well on organics?
- ro taken offline because of high pressure, tried cleaning to no avail, contacted dillion for advice, tried to inject hydrogen peroxide but i am having chemical pump issues,parts ordered,will resume ro operation as soon as possible
- Checking on internet security/water plant dial in program-Delco
- Need clarification on uf integrity testing, daily or on runtime
- hydrant inspection completed , had to rebuild #1 hydrant seat assembly, #18 hydrant changed out sept 27
- 3" LAKE Line ruptured Repaired sept 8/land reclamation has been completed
- Line leak on main to nelson motors, improper installation of valve and coupling caused coupling leak , 6" valve blew off causing the town to be shut down,repared correctly and completed the 6 bactii tests as required(all good)-communication failure between us and wsa resulted in no boil water advisory - who pays?

Equipment and Tools -routine equipment maintenance and repairs on going

- Service equipment as required
- Serviced mini mag hall floor cleaner, parts arrived

Town buildings-no issues –monitoring as required

- Canteen water issues with hose failure , cleaned up and hose ordered

Education

- Book Perry for class #1 ?

Lagoon/sewer-,actizyme being added, logging and testing on going

- inspected all manholes, 13 where cleaned and 4 bottoms need repair, Checking the 4 manholes twice a week for blockages etc.

Grass / Trees- - Mowing as required ,Tree medic on site oct 3/22

- removed and cleaned up trees from various storms, trimming boulevard trees

Streets – Ongoing maintenance