

Update for MAY 22

Landfill-nothing to report- Garbage was Landfilled,No dirt for cover

- Working on information for landfill closure and transfer station operating permit
- working on info going forward to close landfill
- landfill site cleanup ongoing,30 yd bin lasts for 1 month-compiling costs
- water testing this month,6 rat bait stations around site,feeding slowing

Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

- New membranes on site, awaiting cleaning chemicals to practice on uf
- Decided against a coagulant upfront (cost)
- modified chemical and cleaning procedures will be utilized for mag. And organics
- Monday May 30 the hot water tank above control room burst, flooded control room and some items in control panel were shorted out, Delco(chris) brought required parts and repaired, program and set points were loaded and back online 7:30 pm
- Need to replace or eliminate oil Murphy switch on stby pump , has to be manned 24
- Blend is now 1 lt/s total flow is 4.5 lt/s
- high truck fill and redthorpe usages will be addressed going forward for a solution

Equipment and Tools -routine equipment maintenance and repairs on going

- new skid steer tires are required

Town buildings-no issues --monitoring as required

- Replace sump pump old hall

Education

Lagoon/sewer-Lagoon flowing,actizyme being added, logging and testing on going , issues with flow into wetland , may have to jet line

Grass / Trees- - Mowing as required

Streets – Ongoing maintenance ,Street sweeper ready to go

- Culvert markers installed

Water breaks-in front of ron Watsons house went well, his sewer was repaired and pointed out to him the sag

- Dug up mondors again ,our valve okay

- Changed curbstop rod at vals

Saftey - oh&s on site, not many issues ,Jamie has report