

Update for NOV/ 22

Landfill

- Wood pile will be burnt
- bins changed as required

Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

- New membranes on site, awaiting cleaning chemicals to practice on uf
- Cleaned both uf and ro with new chemicals, worked well on organics
- Asked Derek schultz about communications from pump house ,will be supplying options and pricing
- Checking on internet security/water plant dial in program-Delco
- Need clarification on uf integrity testing, daily or on runtime
- RO brought back online nov 3 running great ,suspect lake turnover and we are logging more things on raw water such as temp and conductivity to give us some data to predict what the lake is doing , next hurdle will be manganese so we will be testing for manganese every two days on the raw water , coagulant will have to be used for these events when we predict them, this will reduce coagulant costs and filter trouble
- air compressor unloader valve failed –new on coming,shop air comp running plant REPLACED DEC 9/22
- aov-001 is failing ,uf inlet valve, REPLACED DEC 9/22
- increased clearpac flow rate to 120 ml/hour from 60

Equipment and Tools -routine equipment maintenance and repairs on going

- Service equipment as required

Town buildings-no issues –monitoring as required

- working on office flooring
- Working on clinic bathroom
- Christmas lights up, power issues encountered on 4 poles
- Street lights reported to saskpower and are being replaced now

Education- First aid course completed

Lagoon/sewer-,actizyme being added, logging and testing on going

- Sewer relining-will need a site visit plus camera to determine repair and cost-talked to donna ,will schedule site visit

Grass / Tr

Streets – Ongoing maintenance