

## Update for JUNE 22

### Landfill-nothing to report- Garbage was Landfilled,No dirt for cover

- Working on information for landfill closure and transfer station operating permit
- working on info going forward to close landfill
- landfill site cleanup ongoing,30 yd bin lasts for 1 month-compiling costs
- water testing this month,6 rat bait stations around site,feeding slowing

### Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

- New membranes on site, awaiting cleaning chemicals to practice on uf
- modified chemical and cleaning procedures will be utilized for mag. And organics
- Need to replace or eliminate oil Murphy switch on stby pump , has to be manned 24
- Blend is now 1.5 lt/s total flow is 5 lt/s
- high truck fill and redthorpe usages will be addressed going forward for a solution
- May require new instrumentation on dist. System , pressure switches etc
- Checking on internet security/water plant dial in program

### Equipment and Tools -routine equipment maintenance and repairs on going

- new skid steer tires are installed

### Town buildings-no issues –monitoring as required

### Education

**Lagoon/sewer**-Lagoon flowing,actizyme being added, logging and testing on going , issues with flow into wetland , may have to jet line

**Grass / Trees**- - Mowing as required -

**Streets** – Ongoing maintenance ,Street sweeper ready to go

**Saftey** - oh&s on site, not many issues ,Jamie has report