

Update for FEB / 23

Landfill

-no issues

-bins changed as required

Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

-Feb 13- uf filters would not respond to 4 cleanings so a decision was made to install all 24 new uf filters, this was completed with katrinas help on feb 14, contacted WSA regarding ro unit being taken off line

-Feb 21- Two filters were sent to florida to determine the cause of failure and possible cleaning strategies, awaiting results

- Internet still sporadic,figure sonic wall is the issue ,will do more checking to try and see what system is causing this

*might be possible to get on a pilot using biological filters as a feed to ro ,more news coming.New technology regarding surface water plants.

Equipment and Tools -routine equipment maintenance and repairs on going

-Service equipment as required

Town buildings-no issues –monitoring as required

Education-

Lagoon/sewer

Grass / Trees

Streets – Ongoing maintenance