

Update for April 22

Landfill-nothing to report- Garbage was Landfilled, No dirt for cover

- Working on information for landfill closure and transfer station operating permit
- working on info going forward to close landfill
- landfill covered and site cleanup will begin shortly, New bin ordered

Water plant & Distribution system-lots of fouling issues with uf filter, cleaned and lowered flow

- Ro unit was adjusted for proper flows-100% ro to cistern now
- uf cleaned numerous times, documented results, modified cleaning procedure, sodium hydroxide with chlorine for organics
- organics are an issue, ideas to address this, chlorination, uv etc on raw water
- In touch with Evoqua on changes and questions on operation and maintenance
- Membranes left Australia May 3/22
- Jar testing completed and results look promising using Clearpac plus
- chemicals for cleaning both units being sourced -for organics and manganese

Equipment and Tools -routine equipment maintenance and repairs on going

- Mowers ready to go

Town buildings-no issues –monitoring as required

- Hvac units were serviced ,no issues

Education

Lagoon/sewer-Lagoon flowing, actizyme being added, logging and testing on going

Grass / Trees- - Mowers ready, picking garbage around town/ditches

- Armstrong prep for weed and then seed

Streets – Ongoing maintenance ,Street sweeper ready to go

- Culvert markers will be installed when time permits