

- Update for June 24

Landfill

- bins changed as required, KGS drone survey completed, mowing as required

Water plant & Distribution system

- Procedure needs to be established on priority of distributed water, who will be curtailed in case of low levels, what is a low level? (I will establish a procedure)
Still need ideas to unload the constant demand on plant, screen shots show run hours and peak usage rates, its not sustainable.
- **Moved sample port for continuous monitoring to ro discharge, this will monitor both filters when we start to blend, will need to install program changes for alarms and shutdown logic**
- Uf is running fine
- Working on constant ntu monitoring guidelines, has to be online dec /24
- Met with samson engineering regarding water system assessment and info they require to be ready for grant application for total system upgrade, and possible lift station phase 2 readiness(june27)
- No word from don on data sent to him on blending,will follow up
- Lake line repaired 4th leak so far
- Met with innocorp regarding pilot and setup dates (June 27th)

Equipment and Tools -routine equipment maintenance and repairs on going

STREETS – AWS pavers on site, weather slowing progress, approached coop about cost sharing on there frontage ,and they will

- New signs installed at early learning center

Town buildings- inspecting and repairs as required, order replacement weather stripping for hall doors and steel kick plates for storage room, will install, Rink ice removed and cleaned up, pricing out ramp for clinic

Lagoon/sewer- open, adding actizyme – overland flow valve was cleaned and returned to service

-sewer tanks open and float adjusted for alarm and light.

-**Lift Station**- received quotes on complete pump and control assembly, Asked josh for price on 1500 feet of trench plus two bores , just curious for future expansion

Grass / Trees – Mowing as weather permits,campbell park was rolled with premium 3-way wed control and will monitor

NEW BUSINESS -Auto-cad web-based drafting program, up and running, Tyson working on this, hours are being kept track off.

-**Making a procedure for water restriction guidelines**- Cistern levels at 3.5 will trigger a warning , cistern level of 3.0 will trigger water restrictions and possible outages ,We need a firm guide for restrictions and possible service interruptions . This is required for possible water shortages and to maintain a proper level for service and fire fighting capabilities.

- Tyson completed class 1 water treatment and dist.

- Cleaned up Langley residence and bill submitted